



Energy & Nutrient Optimization of North
North Carolina wastewater treatment
plants: “Wastewater Excellence”

Webinar for North Carolina Wastewater Operators
April 29, 2021
10:00 - 11:45 AM

Brendan Held
Held.Brendan@epa.gov

Terry Albrecht
terry.albrecht@ncdenr.gov

Larry Moore, PhD
mlarry@bellsouth.net

Ron Haynes
rhaynes@wrpnc.org

Grant Weaver, PE & wastewater operator
G.Weaver@CleanWaterOps.com

Webinar Housekeeping

- Technical Difficulties?
- Audio Issues? Use your Phone
 - +1 (415) 655-0060
Access Code: 889-604-561
ID: 944-909-523
- Resource Slides and Recordings
- To Ask Questions
 - Use the Questions Tool on your GoToWebinar Control Panel
- Other issues? Terry Albrecht (828) 707-2834, talbrecht@wrpnc.org

Energy & Nutrient Optimization of NC Municipal Wastewater Treatment Plants

Biological Nitrogen Removal, Parts 1&2


Activated Sludge, Parts 1&2

Biological Phosphorus Review, Parts 1&2

North Carolina Case Studies, Parts 1&2

Energy Management, Parts 1&2

**Today: Wastewater Excellence in North Carolina -
an Overview**





Introducing a new way of thinking:
Facility upgrades aren't the only way
to get nutrient removal...
Empowered operators achieve
amazing results!

Lessons Learned

Biological Nitrogen Removal: 10 mg/L at many (most) activated sludge wwtps

Biological Phosphorus Removal: 1.0 mg/L at many (most) activated sludge wwtps

Many (most) wwtps can reduce their electric bill

Tools are available:

- Bio-Tiger Model
- Nutrient and Energy Assessment Tool
- Nutrient Removal Study Guides
- Course website
- ...and much more

It takes knowledge and courage to transition from PERMIT COMPLIANCE to WASTEWATER EXCELLENCE



7

N

Nitrogen



*Biological Nitrogen Removal:
Convert LIQUID to GAS ...*



*BOD and TSS Removal:
Convert LIQUID to SOLID ...*

Step 1: Convert Ammonia (NH_4) to Nitrate (NO_3)

Oxygen-rich Aerobic Process

Don't need BOD for bacteria to grow

Bacteria are sensitive to pH and temperature

Step 2: Convert Nitrate (NO_3) to Nitrogen Gas (N_2)

Oxygen-poor Anoxic Process

Do need BOD for bacteria to grow

Bacteria are hardy

Phosphorus

15

P

30.974


Phosphorus Removal: What an Operator needs to know

ONE. Convert soluble phosphorus to TSS (total suspended solids)...

Biologically

Chemically

TWO. Remove TSS



Biological Phosphorus Removal

Step 1: prepare “dinner”

VFA (volatile fatty acids) production in anaerobic/fermentive conditions

Step 2: “eat”

Bio-P bugs (PAOs, “phosphate accumulating organisms”) eat VFAs in anaerobic/fermentive conditions ... temporarily releasing more P into the water


Step 3: “breathe” and grow

Bio-P bugs (PAOs) take in almost all of the soluble P in aerobic conditions as they grow and reproduce

First steps for nutrient optimization

- Expand your toolkit for process control sampling
 - Test strips (ammonia, nitrite/nitrate, alkalinity)
 - Spectrophotometer (ammonia, nitrite/nitrate, orthophosphate)
 - Portable DO / ORP meters
 - In-line DO meter
 - Additional in-line instruments (ammonia, orthophosphate ...)
- Manage Regulatory Risk
 - Communication
 - Documentation
 - Ask for help

More on Regulatory Risk...



From Cantor, et al (2021), "Regulators and Utility Managers Agree about Barriers and Opportunities for Innovation in the Municipal Wastewater Sector"

The landscape is changing...

- Some states are requiring optimization as an intermediate step toward nutrient limits
- Other states are offering “safe harbor” letters of support after review of optimization plans, outside of the permitting process
- Any state will require advance communication and strong documentation throughout





Energy Management at Municipal WWTPs

Session Topics:

Organize an Energy Management Program

Energy Vocabulary Literacy

Utility Billing – Understanding your billing

Baseline Data & Tracking (at utility billing level)

Benchmarking

Plant Survey & Evaluations:

Common BMPs for Energy Management



Renewables

OWASA: Energy Management Case Example – Mary Tiger

Resources for Taking the Next Step

Key Takeaways

- Get Familiar with Utility Billing
- Start Tracking Energy Use and Cost Monthly – Make this a KPI!
- Conduct a Plant Assessment for an Energy Balance
- Reach out to Available Resources for Help: Utility, WRP, RWA, Others
- ID Energy Saving Opportunities – Start with no & low cost
- Make your plan!



CITY OF SALISBURY
1915 GRUBB FERRY RD

For more information please call the back of your bill or visit our website at <http://www.duke-energy.com/north-carolina/billing/bark-of-bill.asp>

Account Number [REDACTED]
Verification Code 3
Bill Date 03/19/2021
Current Charges Past Due After 04/05/2021

Service From: FEB 16 to MAR 18 (30 Days)

Your next scheduled meter reading will occur between APR 20 and APR 23

PREVIOUS BILL AMOUNT	PAYMENTS (-)	NEW CHARGES (+)	ADJUSTMENTS (- OR +)	AMOUNT DUE (-)
\$11,149.24	\$11,149.24	\$11,623.02	\$0.00	\$11,623.02

METER NUMBER	METER READINGS: PREVIOUS	METER READINGS: PRESENT	MULTI-PLIER	TOTAL USAGE	RATE SCHEDULE DESCRIPTION	AMOUNT
910567	0.00	1.32	300	396 KW	OPT-V TOU Secondary Small Gen Customer Charge	32.17
	0.00	1.32	300	396 KW	On-Peak Actual Demand (Winter)	
	5621.975	5786.727	300	396 KW	On-Peak Billing Demand	3,815.97
	43114.385	43859.925	300	396 KW	Off-Peak Actual Demand	
				49,426 KWH	On-Peak Energy (Winter)	2,786.34
				174,236 KWH	Off-Peak Energy	4,224.35
					Renewable Energy Rider	3.81
					Sales Tax	760.38
Amount Due						11,623.02

A photograph of industrial machinery at a water treatment plant, featuring large green pipes, blue pumps, and electrical control panels. The scene is dimly lit, with a focus on the mechanical components.

Resources to take the next step

- Duke Energy: Business Energy Advisors and Large Account Reps
- Dominion Energy: RNG Projects (Lee McElrath, Dominion Energy, NC 828-230-7118)
- Your Local COOP/Municipal Utility Reps
- Your Peer Networks: PWOC-WEF
- Your Consulting Engineers
- State Clean Water Grant Sources: Green Project Reserve
- Advanced Energy: Kitt Butler, kbutler@advancedenergy.org
- Energy Efficiency Assessment Providers:
 - Waste Reduction Partners (serving all of NC)
 - Russ Jordan, Energy Manager, rjordan@wrpnc.org, (828) 251-7477
 - NC Rural Water Association (serving populations <10,000)
 - Natalie Narron, Energy Efficiency Circuit Rider, natalienarron@ncrwa.org, (336) 887-0741
 - EPA: Brendan Held & Team Held.Brendan@EPA.gov

Waste Reduction Partners – Energy Assessments



- *Land of Sky's WRP program provides no-cost energy efficiency and waste assessments.*
- *Clients: Any water/wastewater plant, business or institution in NC.*
- *The Team: 40 staff and volunteer engineers (statewide)*
- *Past energy work with: Asheville Water Resources Department, Town of Salisbury, Town of Boone, Cape Fear Public Utility Authority, Kerr Lake, and others*
- *Results: –past 5 years: 275 clients served, \$16.4 million in utility cost savings, 130,000 MWh saved*
- *Initiate a Project: WasteReductionPartners.org or Russ Jordan rjordan@wrpnc.org*



Pilot Plant Updates



Reidsville






Reidsville, North Carolina

Population: 14,000

7.5 MGD design flow



Section 2: Treatment Process Flow Diagram



Reidsville's Action Plan

Phosphorus:

- Already achieving excellent removal, often < 1.0 mg/L
- No additional steps at this time

Nitrogen:

- Effluent currently ~ 10 mg/L
- After diffuser repairs, consider turning off blowers for 1 hour each morning
- Monitor NH_3 and NO_3
- Consider additional 1 hour off cycle in the afternoon
- Continue monitoring performance
- Consider additional off cycles up to four 90-min cycles per day

Questions?

Comments?

Scott Bryan

sbryan@ci.Reidsville.nc.us

Eden Mebane Bridge

CleanB[®]



bcrinc.com
866-724-9145





Eden, North Carolina

Population: 15,000

13.5 MGD design flow

Eden's Action Plan

Phosphorus:

- Already achieving excellent removal, partially due to alum sludge from WTP
- No additional steps at this time

Nitrogen:

- Effluent currently ~10-12 mg/L
- Continuing cycling off 6 of 12 aerators during peak billing hours
- Increase # of “off” aerators to 9, starting 1 hr/d, increase weekly
- Process control sampling for effluent NH₃ and NO₃
- Goal is 8 mg/L TN or less

BioTiger Modeling (Summer months)

Assumptions:

- Alum sludge from WTP means higher than normal inert solids
- Average DO concentration throughout basin is less than DO measured at effluent
- Oxygen supply:
 - 12 x 20 HP aerators running for 16.25 hrs/d
 - 6 x 20 HP aerators running for 7.75 hrs/d
 - This is 4830 HP-hr of aeration per day, so, 201 HP over 24 hrs.
- Plant is fully nitrifying, partially denitrifying
- WAS TSS = RAS TSS

BioTiger Modeling (Summer months)

- Assumption:
 - Alum sludge from WTP means higher than normal inert solids

Activated Sludge Input Data	
Temperature (°C)	25
S _o (mg/L)	160
V (mil gal)	7
Q (mgd)	3.5
Inert VSS (mg/L)	30
Oxidizable N (mg/L)	20
biomass (VSS/TSS)	0.85
Influent TSS (mg/L)	200
Inert Inorg TSS (mg/L)	40
Effluent TSS (mg/L)	4
RAS TSS (mg/L)	4500

BioTiger Modeling (Summer months)

- Assumptions:
 - Average DO concentration throughout basin is less than DO measured at effluent
 - Oxygen supply:
 - 12 x 20 HP aerators running for 16.25 hrs/d
 - 6 x 20 HP aerators running for 7.75 hrs/d
 - This is 4830 HP-hr of aeration per day, so, 201 HP over 24 hrs.

Aerator Performance Data	
Operating DO concentration (mg/L)	1.5
alpha	0.84
beta	0.92
SOTR, lb O ₂ / hp-hr	2.7
Temperature (°C)	25
Aeration (hp) being operated	201
Elevation (ft)	600
Aerators operating time (hr/day)	24
Type of aerators (1, 2, or 3)	1
Speed of aerators (%)	100
Energy cost unit (\$/kWh)	0.05

BioTiger Modeling (Summer months)

Assumptions:

- Plant is fully nitrifying, partially denitrifying
- WAS TSS = RAS TSS

Analysis:

- O₂ supply is within range
- Projected NO₃ (w/o any nitrification) is higher than actual NO₃
- Will not likely reduce NO₃ to 4 mg/L; lower bound of O₂ demand unrealistic
- WAS Q ~50% lower than expected – needs further review

Approximate Operating Conditions	
Total average daily flow rate (mgd)	3.50
Aeration volume in service (mil gal)	7.00
Influent BOD ₅ concentration (mg/L)	160
Influent BOD ₅ mass loading (lb/day)	4,670
Sec ww Oxid N load (lb/day)	584
Sec ww TSS load (lb/day)	5,838
F/M ratio	0.066
Solids Retention Time (day)	46.0
MLSS (mg/L)	2,219
MLVSS (mg/L)	1,208
TSS Sludge Production (lb/day)	2,700
TSS in activated sludge effluent (lb/day)	116.8
Total Oxygen Requirements (lb/day)	8,313
Total Oxygen Req'd W/Denit. (lb/day)	7,448
Total oxygen supplied (lb/day)	8,003
Mixing intensity in the reactor (hp/mil gal)	29
RAS flow rate (mgd)	3.41
RAS recycle percentage (%)	97.3
WAS flow rate (mgd)	0.072
RAS TSS concentration (mg/L)	4,500
Total sludge production (lb/day)	2,816
Reactor Detention Time (hr)	48.0
VOLR (lb BOD/(thou cu ft-day))	4.99
Effluent CBOD ₅ (mg/L)	2.3
Effluent TSS (mg/L)	4.0
Effluent Ammonia-N (mg/L)	0.02
Effluent NO ₃ -N (mg/L)	14.8
Effluent NO ₃ -N W/denit (mg/L)	4.4

BioTiger Modeling (Summer months)

Assumptions:

- WWTP uses ~50% of total electric bill, shared w/ DW Plant

Analysis:

- Aerator electricity use = ~26% of bill, or about 50% of total WWTP
- This seems low for this facility - no aerobic digesters UV disinfection or effluent pumping

Field OTR (lb O2 / hp-hr)	1.66
Aerator energy use (kWh/month)	94,068
Energy cost (\$/month)	4,703

Dec 2020	
Energy Used	351,286 kWh
Days in billing period	30
Average kWh per day	11,710 kWh
Average cost per day	\$506.54

Questions?

Comments?

Melinda Ward
mward@edennc.us

Newton Clark Creek





Newton, North Carolina

Population: 13,000

MGD design flow



Newton's Action Plan

Phosphorus:

- Already achieving excellent removal (<1.0 mg/L avg)
- No additional steps recommended at this time

Nitrogen:

- Effluent TN currently ~25 mg/L with low NH₃
- Evaluate VFDs and SCADA upgrade to allow routine on/off cycling of aerators.
- Start with 90 min off/6 hrs on. Monitor NH₃ and NO₃, and use ORP to fine tune off cycle
- Rough estimate of cost savings: \$40,000/year

Questions?

Comments?

Eric Jones

ejones@newtonnc.gov

Stacy Rowe


srowe@newtonnc.gov

Asheboro





AVERAGES FOR 2020



Influent
Flow Cap 9 MGD
Actual 4.583812

Construction Dates

Start	1962	3 MGD
Upgrade	1975	
Upgrade	1986	6 MGD
Upgrade	1996	9 MGD

Sec SS	41.83472
Sec BOD	42.37137
Sec COD	170.3114

MLSS	2237.056
MLVSS	1673.289
RAS	7076.608
SA	58.75032
MCRT	84.81678
F/M Bod	0.031099
F/M Cod	0.125154

Eff Flow	4.223598
Eff SS	5.289267
Eff BOD	2.797907
Eff Nh3	0.169685

	INF	EFF
BOD	400 mg/l	2.80 mg/l
TKN	31.5 mg/l	1.75 mg/l
NO3+NO2	2.6 mg/l	11.1 mg/l
TP	5.5 mg/l	.34 mg/l
DO in Aeratic	1.8 mg/l	

Sludge Handling System
 3 RSP Pumps 200 gpm
 4 TSP Pumps 200 gpm
 2 DSP Pumps 200 gpm
 2 SFP Pumps 400 GPM
 1 DAF 600 sf
 2 Digesters 400,000 gal
 1 Piston Pump 300 gpm
 2 Ashebrook 1.5 Meter Presses
 16 Drying Beds
 1 Covered Storage Bldg
 1 Uncovered Storage
 Land Application Permitt
 1200 Dry Tons / Year

Gallons		Gallons	
% Poly		%Poly	
% Thick		% Cake	

TRUCK LOADS
 TOTAL CUBIC YARDS PRESS= 0

Previous Optimization Efforts

- Successfully proved we can BNR, more work to do to meet expected permit limits
- Air on for only 12 hrs instead of 24 hrs, huge savings
- Saving in pH adjusting chemical costs because denitrification process recovers pH and alkalinity
- We know what is happening in real time and can react accordingly

Asheboro's Action Plan

Phosphorus:

- Already achieving excellent removal (<1.0 mg/L avg)
- No additional steps recommended at this time
- Long term, consider using intermediate clarifier as side stream fermented

Nitrogen:

- Managing good TN removal using sugar water supplied by cereal manufacturer
- “Reach” goals include routine flooding of trickling filters to eliminate need for off-site carbon
- Consider using intermediate clarifier as side stream fermenter for additional Bio-P

Questions?

Comments?

Mike Wiseman

mwiseman@ci.Asheboro.nc.us

BREAK TIME






Pender County, North Carolina

0.5 MGD design flow

Date	M3 MLSS	MLVSS	INF BOD (mg/l)	INF Flow (MGD)	F/M Ratio	HRT	Aeration Basin DO	INF Ammonia (mg/L)	INF Tphos (mg/L)	INF COD (mg/L)	EFF COD (mg/L)	EFF TSS (mg/L)
12/8/20	3500	1883	454	0.09	0.07	82	3.9	8.97	21.25	2886	43	8
12/9/20	3400	2360	999	0.12	0.16	62	5.1					8
12/10/20	3000	2075	957	0.14	0.21	53	4.3	4.21	10.75	2100	46	8
12/15/20	1650	1075	981	0.13	0.38	57	7.5	7.85	20	2114	91	24
12/16/20	1660	1220	1020	0.13	0.35	57	7.2					17
12/17/20	2040	1500	705	0.11	0.17	67	6.4	4.16	11.5	2078	82	14
12/21/20	3360	2400	234	0.09	0.03	82	4.8					4
12/22/20	3720	2540	595	0.13	0.10	57	4.1	6.34	46.25	1196	102	3
12/23/20	3800	2380	660	0.14	0.13	53	4.5					5
12/30/20	4420	2860	729	0.15	0.12	49	6.4					7
12/31/20	4075	2800	1110	0.15	0.19	49	4.7					2.5
1/5/21	2760	1660	451	0.18	0.16	41	5.3	4.14	16.5	1140	31	3
1/6/21	2540	1600	775	0.18	0.28	41	6.9					2.5
1/7/21	2680	1780	576	0.15	0.16	49	5.9	3.97	10.75	1316	49	2.5
1/12/21	3360	2120	320	0.17	0.08	44	7	3.65	47.25	1348	39	3
1/13/21	4140	2240	395	0.18	0.10	41	4.8					5
1/14/21	4340	2580	332	0.18	0.07	41	6.4	2.95	46.5	1498	48	4
1/19/21	2920	1680	350	0.17	0.11	44	7.5					4
1/20/21	1800	980	405	0.17	0.23	44	5.6					5
1/21/21	1580	4400???	533	0.18	0.07	41	6.7					4
1/26/21	1840	1220	750	0.22	0.44	34	7.1	4.75	63.25	1914	57	2.5
1/27/21	2200	1380	406	0.22	0.21	34	5.2					3
1/28/21	2120	1100	479	0.23	0.32	32	7.2	3.01	6.5	2550	39	3
2/2/21	2700	1340	897	0.22	0.48	34	6.7	10.3	100.25	4050	61	6
2/3/21	3040	1540	721	0.21	0.32	35	6					8
2/4/21	2100	1140	649	0.20	0.37	37	6.5	2.24	9.25	1282	37	4
2/9/21	3820	2300	183	0.19	0.05	39	5.3	2.83	22.75	874	18	2.5
2/10/21	3180	1920	277	0.20	0.09	37	5.9					2.5
2/11/21	2160	1380	290	0.20	0.14	37	6.3	1.46	5.25	784	25	2.5
2/16/21	1320	960	487	0.23	0.38	32	6.4	1.88	7	1018	24	2.5
2/17/21	1920	1260	334	0.23	0.20	32	6.7					2.5
2/18/21	1540	1020		0.22		34	6.1	3.5		1096	26	2.5
Averages	2771	1751	582	0.17	0.20	46	6.0	4.48	27.8	1720	48	5.5




A View of the greenhouse and the office and lab inside the greenhouse.



A View of the
influent
pumping
station



A View of the
chemical
farm, screen
and grit
station, and
the EQ basin.



A View of the
Screen and
grit station.
EQ basin is off
camera to the
right.



A View of the EQ basin from the screen and grit station (off camera behind).



A View of the MBBR with the EQ basin and the secondary clarifiers in the background. Note the black bio-media in the water. These "bio-balls" provide the surface area for additional bacterial growth. Media pictured below.



Left to right:
EQ basin,
secondary
clarifiers,
RAS/WAS
station,
MBBR,
lab/office,
greenhouse/
SFFR.



A View of the interior of the greenhouse / SFFR



A View of the secondary clarifiers with the digesters background left. And RAS/WAS station behind, and to the right of the clarifiers.



A View of
secondary
clarifier 2.



A View of secondary clarifier 1 with the MBBR in the background (right).



A View of the Tertiary filters (left) and the UV disinfecting units (right) with the effluent pump and non-potable water stations behind the UV.



A View of the
UV station
(left), the
tertiary filters
(background
center), the
effluent
pumping
station and
NPW system
(right)



A View of the aerobic digesters.




A fairly clean
overhead
view, north is
straight up.




Effluent total-Nitrogen Pender County, NC

Monthly average tN Rolling AVG tN



Effluent total-Phosphorus Pender County, NC

Monthly Average Rolling 12-mo AVG



Questions?

Comments?

Matt Reeps

mreeps@pendercountync.gov

Grant Weaver – Clean Water Ops
G.weaver@cleanwaterops.com

Mary Tiger – Orange Water And Sewer Authority
Mtiger@owasa.org

Terry Albrecht - Waste Reduction Partners
TAlbrecht@wrpnc.org

Ron Haynes- Waste Reduction Partners
RHaynes@wrpnc.org



Acknowledgements

US EPA

Brendan Held & Craig Hesterlee

NC DEQ / Waste Reduction Partners

Terry Albrecht, Corey Basinger & Ron Haynes

U MEMPHIS

Larry Moore, PhD

ASHEBORO

Mike Wiseman

EDEN

Melinda Ward

NEWTON

Eric Jones, Stacy Rowe

PENDER COUNTY

Matt Reeps

REIDSVILLE

Scott Bryan

